



STC Test Report

Date : 2015-07-29
No. : HC370653

Page 1 of 2

Applicant (Code: SHM019) : 生命之源
九龍青山道 479 號麗昌工廠大廈 3 樓 3030

Description of Sample(s) : Two submitted samples said to be Water.

Sample(s) Received Condition(s): In plastic bottle provided by client under ambient temperature

Date Sample(s) Received : 2015-07-27

Date Tested : 2015-07-27 to 2015-07-29

Investigation Requested : Lead content 鉛含量

Method(s) Used : Inductively Coupled Plasma – Mass Spectrometry

TAM Leong Hang, Anthony
Authorized Signatory
Chemical and Food Department
For and on behalf of

The Hong Kong Standards and Testing Centre Ltd.



In the event of any discrepancy between the English and Chinese versions of the text mentioned before, the English version shall prevail to the extent of such discrepancy only.

The Hong Kong Standards and Testing Centre Limited 香港標準及檢定中心有限公司

10 Dai Wang Street, Tai Po Industrial Estate, Tai Po, N.T., Hong Kong 香港新界大埔工業邨大宏街10號

Tel: +852 2666 1888 Fax: +852 2664 4353 E-mail: hkstc@hkstc.org Website: www.stc-group.org

This report shall not be reproduced unless with prior written approval from The Hong Kong Standards and Testing Centre Limited.

For Conditions of Issuance of this test report, please refer to the overleaf and Website.

除非事先得到香港標準及檢定中心有限公司的書面批准，否則不得自行復印此報告。測試報告相關的簽發條件，請參閱背頁和本公司網頁。



STC Test Report

Date : 2015-07-29
No. : HC370653

Page 2 of 2

Test Result(s):

Sampling at : 聯悅樓

Sample(s)	Lead content 鉛含量	WHO Guidelines#
3020	21.1 µg/L	10 µg/L
3020 室(阿里郎)	Not Detected	

Notes: - # Guidelines for Drinking-water Quality, Fourth Edition , World Health Organization (WHO) Geneva 2011

- Method Detection Limit of lead content is 5µg/L

- µg/L denotes microgram per Liter

******* End of Test Report *******

The Hong Kong Standards and Testing Centre Limited 香港標準及檢定中心有限公司

10 Dai Wang Street, Tai Po Industrial Estate, Tai Po, N.T., Hong Kong 香港新界大埔工業邨大宏街10號

Tel: +852 2666 1888 Fax: +852 2664 4353 E-mail: hkstc@hkstc.org Website: www.stc-group.org

This report shall not be reproduced unless with prior written approval from The Hong Kong Standards and Testing Centre Limited.

For Conditions of Issuance of this test report, please refer to the overleaf and Website.

除非事先得到香港標準及檢定中心有限公司的書面批准，否則不得自行復印此報告。測試報告相關的簽發條件，請參閱背頁和本公司網頁。